



Lassen County Environmental Health Division
 1445 Paul Bunyan Road, Suite B, Susanville, CA 96130
 TELEPHONE: (530) 251-8528 FAX: (530) 251-2668

SWIMMING POOL INSPECTION REPORT

| | | | | | | | | |
|---|--|--|------------------|---------------------------------|------------------|------------------------------|-----------------------|---------------------|
| DBA/NAME <i>Red Lion Inn & Suites</i> | | | | | | DATE <i>6/11/2019</i> | | |
| ADDRESS <i>3015 Riverside Drive</i> | | | | CITY | | RECHECK DATE | | |
| OWNER/OPERATOR <i>Triple O Investment Inc</i> | | | | SERVICE | | SPA TEMPERATURE <i>87</i> °F | | |
| POOL TYPE / PR# <i>Spa</i> | DISINFECTANT RESIDUAL <i>12</i> ppm | COMBINED CHLORINE RESIDUAL <i>N/A</i> ppm | pH <i>7.2</i> | CYANURIC ACID <i>N/A</i> ppm | FLOW RATE gpm | INFLUENT GAUGE psi | EFFLUENT GAUGE psi | VACUUM GAUGE psi |
| POOL TYPE / PR # | DISINFECTANT RESIDUAL ppm | COMBINED CHLORINE RESIDUAL ppm | pH | CYANURIC ACID ppm | FLOW RATE gpm | INFLUENT GAUGE psi | EFFLUENT GAUGE psi | VACUUM GAUGE psi |
| POOL TYPE / PR # | DISINFECTANT RESIDUAL ppm | COMBINED CHLORINE RESIDUAL ppm | pH | CYANURIC ACID ppm | FLOW RATE gpm | INFLUENT GAUGE psi | EFFLUENT GAUGE psi | VACUUM GAUGE psi |

The checked items represent violations and must be corrected as follows:

WATER CHEMISTRY *Spa Bromine min 4.0 ppm*

- Maintain a free chlorine residual between 1.0 ppm and 10.0 ppm, or 2.0 and 10.0 ppm if cyanuric acid is used, in swimming pools.
- Maintain a free chlorine residual between 3.0 and 10.0 ppm in spas, wading pools and spray grounds at all times.
- Maintain the level of combined chlorine between 0.4 ppm at all times.
- Maintain a pH between 7.2 and 7.8.
- Maintain the level of cyanuric acid below 100 ppm.

EQUIPMENT

- Backwash the filter(s).
- Provide, repair, or replace the vacuum gauge and/or influent/effluent pressure gauge(s).
- Provide, repair, or replace the flowmeter.
- Maintain disinfectant to the automatic feeder.
- Operate the recirculation system, including the disinfectant feeder, at all times the facility is open for use or longer as necessary to maintain the water clean and clear.

RESTROOMS

- Showers and lavatories shall be provided with hot (max. 110 degrees Fahrenheit) and cold running water.
- Provide soap in permanently installed soap dispensers, sanitary towels or hot air blowers, and toilet tissues at toilet facilities.

MAINTENANCE AND SUPERVISION

- Provide / maintain a self-closing gate / door to pool area with self-latching hardware at least 42 inches above finished grade.
- Maintain skimmer in good working order; weir assembly, strainer basket and diverter valve assembly are required.
- Limit spa pool water temperature to a maximum of 104 degrees Fahrenheit.
- Replace broken / missing / unreadable depth marker tiles and / or pool tiles.
- Secure / replace drain cover with an approved type which can only be removed with tools. Main drain must be clearly visible at all times.
- Provide / repair / replace the safety vacuum release system (SVRS).
- Secure / repair / replace loose stair handrail(s) / ladder / ladder step treads / grab rails.
- Maintain a daily log of the pool operation, disinfectant residual, combined chlorine, pH and maintenance procedures.
- Provide an approved DPD test kit.
- Provide keys to this department to gates / doors / equipment room(s) / and / or restroom facilities for inspection.

SAFETY EQUIPMENT AND SIGNS – SEE REVERSE FOR SAFETY EQUIPMENT AND SIGN REQUIREMENTS

- All safety equipment must be readily accessible to pool users. All required signs must be clearly visible from the pool deck.
- SAFETY EQUIPMENT: Rescue Pole Life Ring
- SIGNS: Artificial Respiration and CPR Emergency Phone Numbers Occupant Capacity P/S No Lifeguard on duty
- Spa Caution Emergency Shut-Off Switch Keep Closed No Diving Allowed
- Emergency Exit Diarrhea Other

Pursuant to California Code of regulations, Section 65545, THIS POOL/SPA IS OFFICIALLY CLOSED. This pool shall not be placed in operation until all violations have been corrected and upon specific written approval by this Division. Call to schedule a reinspection. DO NOT REMOVE THE CLOSED SIGN.

| | | | |
|--|-------------------------------|---------|------------------------------------|
| Environmental Health Specialist: <i>[Signature]</i> | Phone: <i>530-251-8528</i> | Page of | Received by: <i>[Signature]</i> |
|--|-------------------------------|---------|------------------------------------|

Spa Approved to open

DISTRIBUTION: White – Office Canary – Owner's Copy